

RG-03 : SE-325 NEUTRAL-GROUNDING-RESISTOR MONITOR SETTING

Substation Identification: _____

Secondary Voltage: _____

SE-325 Model Number and Serial Number: _____

Ground-Fault Trip Level

Check One	GF Setting
☐	4 A
☒	2 A
☐	0.5 A

Ground-Fault Trip Time

Setting: _____ seconds

Output Contact Mode of Operation

Check One	Mode Setting
☐	SH (Shunt Trip)
☒	UV (Undervoltage Trip)

Sensing Resistor

Check One	Model
☐	ER-600VC
☒	ER-5KV
☐	ER-15KV
☒	ER-25KV
☐	ER-35KV

RES

Check One	NGR Resistance
☐	100K
☒	20K

RES Trip Lvel (Vac)

For RES = 100K

Range is 100 to 2000 Vac

Setting: _____

For RES = 20K

Range is 20 to 400 Vac

Setting: _____

Remote Indication

Check One	Model
☐	None
☒	RK-13 Relay Interface Module
☐	RK-302 Remote Indication and Reset Kit
☒	RK-325 Remote Indication and Reset Assembly
☐	RK-325I Remote Indication Assembly

NGR Ratings

Current: _____ A

Voltage: _____ V

Current Transformer

Check One	CT Size
☐	CT200, 56 mm (2.2") Inner Diameter
☒	CT200L, 89 mm (3.5") Inner Diameter