



11.5 TECHNICAL INFORMATION

TITLE: POLYCAST 200:5 CT TEST

CT: Polycast Industrial Products

ACCUR: 10L20

ID: 932-HBC-05R

SER: 25001-1

RATIO: 200:5

INS.CL: 600 V

This CT was tested with a SE-325. Test results as follows:

SE-325 TRIP SETTING	POLYCAST 200:5 TRIP LEVEL	ACCEPTANCE RANGE
0.5 A	0.49 A	0.4 A to 5.5 A
2.0 A	1.75 A	1.6 A to 2.3 A
4.0 A	3.5 A	3.2 A to 4.4 A

This CT meets the acceptance range specification for the SE-325.

DATE	REV	AUTHOR	DOCUMENT LOCATION	PAGE
1997-Jul-04	0	MV	http://www.startco.ca/library/techinfo/section11/11.5.pdf	1 of 1